



## Certificate

www.bsria.co.uk

Certificate No.: C18290/2 Issue: 1 Date of issue: 16<sup>th</sup> December 2003

This is to certify that

*BSRIA Ltd.*

has type tested the following product described below to the requirements contained in  
The Heating and Ventilating Contractors Association Test method DW/TM1  
'Ductwork - Acceptance scheme for new products - Rectangular cross joint  
classification'.

Product covered by this certificate

*DW30/1.0*

Manufacturer

*DE WAAL STAAL  
DR. H. VAN DOOREWEG 34  
5753 PM DEURNE  
THE NETHERLANDS*

Product drawing reference number

*W 10160*

General Description

*Galvanised steel knock on flange, 1.0 mm thick with associated corners, and clamps.*

Associated components

Corner: *ST12020*

Clamps : *G15010 at 300mm centres*

Tape : *15323 gasket seal*

### Test Results

Rating : *J3*

Classes : *A, B, and C*

Date of testing : *14<sup>th</sup>, 15<sup>th</sup>, and 16<sup>th</sup> October 2003*

Test report reference number : *18290/1 dated October 2003*

Test Engineer : *P J Heywood*

Quality Approved: .....

  
*P Stonard*

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is for the sole and specific use of De Waal Staal and should only be used for the purposes for which it was prepared and provided.

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

Page 1 of 2

T : +44 (0)1344 426511 F : +44 (0)1344 487575

E : [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W : [www.bsria.co.uk](http://www.bsria.co.uk)



## Certificate

[www.bsria.co.uk](http://www.bsria.co.uk)

**Certificate No.:** C18290/3    **Issue:** 1    **Date of issue:** 16<sup>th</sup> December 2003

This is to certify that

*BSRIA Ltd.*

has type tested the following product described below to the requirements contained in  
The Heating and Ventilating Contractors Association Test method DW/TM1  
'Ductwork - Acceptance scheme for new products - Rectangular cross joint  
classification'.

Product covered by this certificate

*DW30/1.0*

Manufacturer

*DE WAAL STAAL  
DR. H. VAN DOOREWEG 34  
5753 PM DEURNE  
THE NETHERLANDS*

Product drawing reference number

*W 10160*

General Description

*Galvanised steel knock on flange, 1.0 mm thick with associated corners, and clamps.*

Associated components

*Corner: ST12020*

Clamps : *G15010 at 300mm centres*

Tape : *15323 gasket seal*

### Test Results

**Rating :** *J4*

**Classes :** *A, B, and C*

Date of testing : *14<sup>th</sup>, 15<sup>th</sup>, and 16<sup>th</sup> October 2003*

Test report reference number : *18290/1 dated October 2003*

Test Engineer : *P J Heywood*

Quality Approved: .....

  
*P Stonard*

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is for the sole and specific use of De Waal Staal and should only be used for the purposes for which it was prepared and provided.

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire - RG12 7AH UK

Page 1 of 2

T : +44 (0)1344 426511 F : +44 (0)1344 487575

E : [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W : [www.bsria.co.uk](http://www.bsria.co.uk)