



Certificate

www.bsria.co.uk

Certificate No.: C18290/4 Issue: 1 Date of issue: 16th December 2003

This is to certify that

BSRIA Ltd.

has type tested the following product described below to the requirements contained in
The Heating and Ventilating Contractors Association Test method DW/TM1
'Ductwork - Acceptance scheme for new products - Rectangular cross joint
classification'.

Product covered by this certificate

DW40/1.25

Manufacturer

*DE WAAL STAAL
DR. H. VAN DOOREWEG 34
5753 PM DEURNE
THE NETHERLANDS*

Product drawing reference number
10180

General Description

Galvanised steel knock on flange, 1.25 mm thick with associated corners, and clamps.

Associated components

Corner: *ST120303*

Clamps : *G15010 at 300mm centres*

Tape : *15323 gasket seal*

Test Results


Rating : *J4*

Classes : *A, B, and C*

Date of testing : *14th, 15th, and 16th October 2003*

Test report reference number : *18290/1 dated October 2003*

Test Engineer : *P J Heywood*

Quality Approved:.....
P Stonard

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is for the sole and specific use of De Waal Staal and should only be used for the purposes for which it was prepared and provided.

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

Page 1 of 2

T : +44 (0)1344 426511 F : +44 (0)1344 487575

E : bsria@bsria.co.uk W : www.bsria.co.uk



Certificate

www.bsria.co.uk

Certificate No.: C18290/5 **Issue:** 1 **Date of issue:** 16th December 2003

This is to certify that

BSRIA Ltd.

has type tested the following product described below to the requirements contained in
The Heating and Ventilating Contractors Association Test method DW/TM1
'Ductwork - Acceptance scheme for new products - Rectangular cross joint
classification'.

Product covered by this certificate

DW40/1.25

Manufacturer

*DE WAAL STAAL.
DR. H. VAN DOOREWEG 34
5753 PM DEURNE
THE NETHERLANDS*

Product drawing reference number

10180

General Description

Galvanised steel knock on flange, 1.25 mm thick with associated corners, and clamps.

Associated components

Corner: ST120303

Clamps : G15010 at 300mm centres

Tape : 15323 gasket seal

Test Results

Rating : J5

Classes : A, B, and C
(Class B with Tie rod)

Date of testing : 14th, 15th, and 16th October 2003

Test report reference number : 18290/1 dated October 2003

Test Engineer : *P J Heywood*

Quality Approved:.....
P Stonard

This certificate must not be reproduced except
in full without the written approval of an
executive director of BSRIA. It is for the sole
and specific use of De Waal Staal and should
only be used for the purposes for which it was
prepared and provided.

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

Page 1 of 2

T : +44 (0)1344 426511 F : +44 (0)1344 487575

E : bsria@bsria.co.uk W : www.bsria.co.uk



BSRIA

Certificate

www.bsria.co.uk

Certificate No.: C18290/6 Issue: 1 Date of issue: 16th December 2003

This is to certify that

BSRIA Ltd.

has type tested the following product described below to the requirements contained in
The Heating and Ventilating Contractors Association Test method DW/TM1
'Ductwork - Acceptance scheme for new products - Rectangular cross joint
classification'.

Product covered by this certificate

DW40/1.25

Manufacturer

*DE WAAL STAAL
DR. H. VAN DOOREWEG 34
5753 PM DEURNE
THE NETHERLANDS*

Product drawing reference number
10180

General Description

Galvanised steel knock on flange, 1.25 mm thick with associated corners, and clamps.

Associated components

Corner: ST120303

Clamps : G15010 at 300mm centres

Tape : 15323 gasket seal

Test Results

Rating : J6

Classes : A, B, and C
(with tie rods)

Date of testing : 14th, 15th, and 16th October 2003

Test report reference number : 18290/1 dated October 2003

Test Engineer : P J Heywood

Quality Approved:.....



P Stonard

This certificate must not be reproduced except
in full without the written approval of an
executive director of BSRIA. It is for the sole
and specific use of De Waal Staal and should
only be used for the purposes for which it was
prepared and provided.

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

Page 1 of 2

T : +44 (0)1344 426511 F : +44 (0)1344 487575

E : bsria@bsria.co.uk W : www.bsria.co.uk